




KIT DWSUSP

MOUNTING ACCESSORY KIT
FOR ILBDW SERIES EMERGENCY
LED DRIVERS

(520) 294-3292 • www.iotaengineering.com

The KIT DWSUSP accessory kit may be used to suspend an IOTA ILBDW Series Emergency LED Driver using aircraft cables (not provided) or a chain and S-hook (not provided). See the ILBDW specification sheet for unit weight before suspending to ensure facility mounting points are acceptable.

 **The ILBDW must be oriented such that the arrow on the unit label faces up after the ILBDW is suspended.**

Installation Instructions

1. Route the cable or S-hook (not provided) through the mounting slots on each KIT DWSUSP bracket (see *Illustration 1*).
2. For each KIT DWSUSP bracket, hang the ILBDW unit on one edge of the bracket and rotate the ILBDW up to snap in the other side of the bracket.
3. Once both brackets are attached to the ILBDW, the unit may be lifted to its final suspended position.

*Illustration 1: Routing cable through
KIT DWSUSP mounting slots*





Illustration 2: Attaching ILBDW to brackets



Replacing Unit

To replace the ILBDW model, lower the unit from the mounting points, then remove the cable or S-hook. Press the ILBDW towards one end of each KIT DWSUSP bracket until the unit may be lifted off the adjacent end. Follow the Installation Instructions to connect the replacement.