


APPLICATION GUIDE: STANDARD SPECIAL SIGNAGE

Lithonia Lighting offers special signage signs to suit many applications. The Signature and Quantum families highlighted below are illuminated with energy-efficient, long-life Light Emitting Diodes (LEDs). **WARRANTY** — This is the only warranty provided and no other statements in this specification sheet create any warranty of any kind. All other express and implied warranties are disclaimed. Complete warranty terms located at: <u>www.acuitybrands.com/support/warranty/terms-and-conditions</u>

Note: Actual performance may differ as a result of end-user environment and application. Specifications subject to change without notice.

Catalog Number	
Notes	
Туре	



CUSTOM SIGNAGE

Example: LQM P W 3 R 120/277 SW02 Break out as: LQM P W 3 R 120/277 SW00 M6 SPLQM W R SW02 A0FRSU S31

Example: LEPW1RSW02

Family ^{1,2} Face type Housing color		Number of faces	Letter color	Input voltage	Operation	
LQM Quantum® thermoplastic sign	P Panel	W White	3 Single face with extra faceplate and color panel	R Red G Green	120/277 Dual voltage	(blank) AC only

Notes

1 See spec sheet LQM for complete fixture specifications. Not available with other options or battery back-up (EL N).

2 Not available with single (1) or double (2) face.

ORDERING INFORMATION Lead times will vary depending on options selected. Consult with your sales representative. Break out as: LE P W 1 R SWO						
Family ¹	Face type	Housing color	Number of faces	Letter color	Input voltage	Operation
LE Signature® die-cast aluminum sign	P Panel	(blank) Matte black, brushed aluminum face W White	1 Single face 2 Double face	R Red G Green	(blank) 120 thru 277V, 50/60hz	(blank) AC only EL N Nickel-cadmium battery

Notes

1 See spec sheet <u>LE</u> for complete fixture specifications. Not available with other options.

Special wording							
SW01 SW02 SW03 SW04 SW05	AREA OF REFUGE ¹ AREA OF RESCUE ¹ AREA OF RESCUE ASSISTANCE ¹ AREA OF RESCUE ASSISTANCE with access pictogram ¹ BEAM IN USE ^{1,2}	SW06 SW07 SW08 SW09 SW10	DARK ROOM IN USE ^{1,2} EXIT Arabic/English ^{3,4} EXIT with access pictogram ⁴ IN USE ^{1,2} LASER IN USE ^{1,2}	SW11 SW12 SW13 SW14	MAGNET IN USE ^{1,2} NO EXIT ⁴ ON AIR ^{1,2} ROOM IN USE ^{1,2}	SW15 SW16 SW17 SW18 SW19	SALIDA ⁴ X-RAY IN USE ^{1,2} Handicap Symbol ¹ MRI IN USE ^{1,2} BEAM ON ^{1,2}

Notes

1 UL48 listing as an electric sign only.

2 Not available with EL N operation.

3 Only available in red letters.

4 Not available with UL924 listing.

MAINTENANCE

All life safety equipment, including emergency lighting for path of egress must be maintained, serviced, and tested in accordance with all National Fire Protection Association (NFPA) and local codes. Failure to perform the required maintenance, service, or testing could jeopardize the safety of occupants and will void all warranties.

🜔 LITHONIA LIGHTING