



Catalog Number	
Notes	
Туре	

Contractor Select™

EI500

Flourescent Battery Pack

The Lithonia Lighting® low-profile EI500 Fluorescent Battery Pack by Power Sentry® provides 90 minutes of emergency power for fluorescent fixtures in the case of a loss in power.



- Integrated test switch pilot light
- Field installable only
- For use with Dual-voltage (120/277V)



Catalog Number	UPC	Description	Voltage	Input Amps 120/277	Wattage	Pallet Qty	Carton Qty
EI500 M12	745973432075	500-lumen fluorescent battery pack	120/277V	0.27/0.26	2.3W	576	12

CONTRACTOR SELECT EI500 Page 1 of 2





Specifications

INTENDED USE:

Operates one 2' or 4' linear or U-shaped T8 or T12 fluorescent lamp for 90 minutes. Compatible with electronic T8 and magnetic T12, instant-start, rapid-start and slimline ballasts. Field-installable only within fluorescent fixture ballast channel. Battery pack automatically operates lamp at reduced light output upon interruption of normal power for 90 minutes of illumination.

CONSTRUCTION:

Black 20-gauge steel, permanently sealed housing. Patent-integrated test switch pilot light that requires only one-hole drilling. US Patent No. 6,522,147.

ELECTRICAL:

Dual voltage input capability (120V or 277V). Constant-current type charger. Capacitive input circuit provides high efficiency and reliable operation.

Battery: Sealed, maintenance-free, high-temperature nickel cadmium battery ensures long life over wide temperature ranges. Automatic battery recharge after 90-minute discharge. Fully charged after 72 hours.

LISTINGS:

UL Listed. Meets UL 924, NFPA 101, NFPA 70-NEC and OSHA illumination standards. Standard unit is UL approved for installation in sealed and gasketed fixtures.

WARRANTY:

1-year limited warranty. Complete warranty terms located at: www.acuitybrands.com/CustomerResources/Terms_and_conditions.aspx

All life safety equipment, including emergency lighting for path of egress must be maintained, serviced, and tested in accordance with all National Fire Protections Association (NFPA) and local codes. Failure to p erform the required maintenance, service, or testing could jeopardize the safety of occupants and will void all warranties.

Note: Actual performance may differ as a result of end-user environment and application. Specifications subject to change without notice.

Dimensions

All dimensions are inches (centimeters) unless otherwise indicated.

